



## ZHEJIANG YONGHE REFRIGERANT CO., LTD.

### Certificate of Analysis

Product: R410A

Batch No.: 1-2001131

Standard: Q/ZYH 013-2019

The date of report: 20200114

Items	Unit	Index	Inspection Results
Appearance		Colorless and clear	Qualified
Odor		No strange odor	Qualified
Purity	% ( $\geq$ )	99.50	99.95
R32/R125 %		48.5-50.5/49.5-51.5	49.7/50.3
Moisture	% ( $\leq$ )	0.0030	0.0009
Acidity	(as HCL) %	0.0001	<0.0001
Vapor Residue	% ( $\leq$ )	0.010	<0.010
Non condensable gases	% ( $\leq$ )	1.5	0.9
Conclusion	Qualified		
Remark	浙江永和制冷股份有限公司 ZHEJIANG YONGHE REFRIGERANT CO.,LTD. XB605/YH2005-2		

Inspector: Chen Shujie

Review: Liu Wangxing

Check: Ke Xuemei